

State of Vermont
Department of Environmental Conservation

Agency of Natural Resources

DUBOIS & KING, INC.

FILE # _____

SUBJ _____

103 South Main Street
Building 10 North
Waterbury, VT 05671-0408

MAR 27 2007

FAX 802-241-3287

TEL 802-241-3770

REFD TO: _____

March 23, 2007

NOTED: _____

John Benson
DuBois & King
P.O. Box 339
Randolph, VT 05060

RE: Bellows Falls Substation


Dear John,

I have reviewed the information and plans that were sent to the Water Quality Division by Patrick Kearney, of Green Mountain Power, regarding the Bellows Falls Substation Relocation project. The information provided indicates that the total lot size is less than one acre. As the Construction General Permit threshold for requiring coverage under that permit is one acre of earth disturbance, this project is not required to obtain coverage under the Construction General Permit. Additionally, as the threshold for requiring an operational stormwater discharge permit is also one acre, this project is not required to obtain coverage under an operational permit.

In conclusion, neither a construction, GP 3-9020, nor operational, GP 3-9015, stormwater discharge permit is required for this project.

If you have questions on the standards or regulations please feel free to contact me. My phone number is 802-241-3679, and my e-mail address is dan.mason@state.vt.us.

Sincerely,



Daniel Mason
Environmental Analyst
Stormwater Section

CC: Patrick Kearney

